



# DECLARATION

## Declaration of Compliance



**Applicant:** FOXESS CO., LTD.  
Peter-Sander-Straße 13  
55252 Wiesbaden  
Germany

**Product type:** Switching box

**Model:** EPS BOX PRO

**Rating:**

Utility Supply	
Rated voltage:	220/380 Vac 230/400 Vac
Rated frequency:	50/60 Hz
Max. current (per phase):	63 A
Inverter grid	
Rated voltage:	220/380 Vac 230/400 Vac
Rated frequency:	50/60 Hz
Max. current (per phase):	25 A
Inverter EPS	
Rated voltage:	220/380 Vac 230/400 Vac
Rated frequency:	50/60 Hz
Max. current (per phase):	25 A
Load	
Rated voltage:	220/380 Vac 230/400 Vac
Rated frequency:	50/60 Hz
Max. current (per phase):	63 A
General Data	
Communication interface:	RS-485 (Meter)
Operating temperature range:	-25~+60°C
Ingress protection:	IP65

A representative test sample of above stated model passed the tests according to:

**Standard:** VDE-AR-E 2510-2:2021-02

**Report no:** 24PP203-01\_0

**Declaration no:** 24-415-00

**Date of issue:** 2024-12-16

**Kiwa Primara GmbH**  
Gewerbestraße 28 - 32  
87600 Kaufbeuren  
Germany  
Tel. +49 8341 99726-0  
primara@kiwa.com  
www.kiwa.de

**Michael Schugg**

