

Camignone di Passirano 13/07/2020

**DECLARATION OF PERFORMANCE**  
**No. DoP 00018**

**Unique identification code of the product-type**

H1Z2Z2-K II Sect. 4 mm<sup>2</sup> diam. 5,60 mm

**Intended use**

Power, control and communication cables – Cables for general application in construction works subjected to reaction to fire requirements

**Producer**

Elettro Brescia S.p.A.  
Via Bulloni 36  
I – 25050 Camignone di Passirano (BS)

**AVCP SYSTEM**

1+

**Classification report No**

C 0001055

**Harmonized Standard**

EN 50575:2014 + A1:2016

**Notified Body**

2479 – L.S. Fire Testing Institute S.r.l.

Notified product certification body no. 2479 performed the determination of product type, the initial inspection of the manufacturing plant and of FPC, the continuous surveillance, assessment and evaluation of the FPC and the audit testing of samples taken before placing the product on the market and issued the certificate of constancy of performance.

**Agent**

N.A.

**Declared performance**

Fire Reaction: Cca-s1,d2,a1  
Dangerous substances: none

This declaration of performance is issued under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

Marco Del Corno  
Quality and Laboratory Manager

