



MCS Product Certificate

Date Issued: 14/07/2021 Annual review date: 7th March
Issue number: 5 Original/Amendment: Amendment
Certificate number: KIWA00002 Page: 1 of 2

MCS Product Certification Certificate Issued by Kiwa Ltd

MCS Product Certification Scheme Standards – MCS010, MCS011, MCS012
Model designations – see Appendix

Producer:

Esdec BV

Londenstraat 16
Deventer
7418 EE
The Netherlands

Manufacturer:

As Above

Kiwa Ltd declares that the products detailed in the Annex have been assessed by Kiwa and meet the requirements of the above MCS Product Certification Standards.

Signed on behalf of Kiwa Ltd

Mark Crowther, MCS Certification Director
Kiwa Ltd

*This certificate consists of 2 pages.
Publication of this certificate is permitted.*





MCS Product Certificate

Appendix to Certificate KIWA00002

Page 2 of 2

The following products have been assessed and registered by Kiwa Ltd against the provisions of:

MCS 010, MCS 011, MCS 012

Product Name	Model Name	MCS Certificate Number
ClickFit EVO Range	ClickFit EVO Tiled Roof	KIWA 00002/004 IK
Range of Permissible Roof Pitch (degrees)	>25	
Compatible Roof Coverings	Tiled roofs with wooden substructure	
Roofing Substrate For certified wind uplift resistance in sound timber	Min rafter size (h x w mm)	Roofing Substrate For certified wind uplift resistance in sound timber
	150 mm x 55 mm	48 mm x 21 mm
Further notes on fixing (where relevant)	<i>Tiles may need to be ground in accordance with manufacturer instructions to ensure satisfactory fitting of mounting hooks.</i>	
Maximum Design Wind Uplift Calculated by dividing the characteristic wind uplift by the partial safety factor shown below	1.45kPa for arrays using 3 roof hooks per 1.64 m x 0.992 m panel	
Partial (safety) factor(s)	1	
Fire Classification	NA	
Limitations on Fire Classification	This kit is suitable for: Above roof installations over non-flammable outer roof covering only	

Signed on behalf of Kiwa Ltd

Mark Crowther
MCS Certification Director
Kiwa Ltd

This certificate is subject to the producer continuing to comply with the Kiwa MCS Product Scheme Rules and ongoing Annual Surveillance



CERTIFICATE