




锂电池 UN38.3 试验概要 Lithium Battery Test Summary

项目编号: AGC09609230201UA04

单位信息 Company Information					
委托单位 Consignor	深圳市格伏恩新能源科技有限公司 广东省深圳市宝安区燕罗街道燕川社区兴达路 38 号厂房 201 电话/Tel: 13631646261 邮箱/Mail: bella.liu@givenergy.cn				
生产单位 Manufacturer	深圳市格伏恩新能源科技有限公司 广东省深圳市宝安区燕罗街道燕川社区兴达路 38 号厂房 201 电话/Tel: 13631646261 邮箱/Mail: bella.liu@givenergy.cn				
测试单位 Test Lab	深圳市鑫宇环检测有限公司 深圳市宝安区福海街道和平社区重庆路骏丰工业园厂房 19 栋第一、二层 电话/Tel: +86-755-2523 4088 邮箱/Mail: agc@agccert.com 网址/Website: www.agccert.com				
电池信息 Battery Information					
名称 Name	可充电锂离子电池 Rechargeable Li-ion Battery	电池/电芯类别 Battery/Cell Classification		锂离子电池 Li-ion Battery	
型号 Type	GIV-BAT-3.4-HV	商标 Trademark		GivEnergy	
额定电压 Normal Voltage	76.8V	额定容量 Rated Capacity		52Ah	
额定能量 Watt-hour rating	52Ah	外观/Appearance		白色近长方体 Approximate White Cuboid	
质量/Mass	34.45KG	锂含量/Li Content		不适用 N/A	
测试信息 Test Information					
测试报告编号 Test Report Number	AGC09609230201UA01	测试报告签发日期 Date of Test Report		2023-04-06	
测试标准 Edition of UN Manual of Tests and Criteria Used	联合国《试验和标准手册》(第 7 版修订 1) 38.3 节 UN "Manual of Tests and Criteria" ST/SG/AC.10/11/Rev.7/Amend1/Subsection 38.3				
T.1: 高度模拟 Altitude Simulation	通过 Pass	T.2: 温度试验 Thermal Test	通过 Pass	T.3: 振动 Vibration	通过 Pass
T.4: 冲击 Shock	通过 Pass	T.5: 外部短路 External Short Circuit	通过 Pass	T.6: 撞击/挤压 Impact/Crush	通过 Pass
T.7: 过度充电 Overcharge	通过 Pass	T.8: 强制放电 Forced Discharge	通过 Pass		
UN38.3.3(f)	不适用 N/A		UN38.3.3(g)		
签名 Signatory 职务 Title	肖旭东 检验员		签发日期 Issued Date	2023-04-06	



Any report having not been signed by authorized approver, or having been altered without authorization, or having not been stamped by the "Dedicated Testing/Inspection Stamp" is deemed to be invalid. Copying or excerpting portion of, or altering the content of the report is not permitted without the written authorization of AGC. The test results presented in the report apply only to the tested sample. Any objections to report issued by AGC should be submitted to AGC within 15days after the issuance of the test report. Further enquiry of validity or verification of the test report should be addressed to AGC by agc01@agccert.com.